




TOWN OF WINCHESTER
71 MT. VERNON STREET, WINCHESTER, MA
ENGINEERING DEPARTMENT
PHONE 781-721-7120

TO: Lisa Wong, Town Manager
FROM: Beth Rudolph, P.E., Town Engineer 
DATE: April 7, 2021
RE: Eversource Grant of Location Petition – Swanton Street

The Engineering Department has reviewed the Eversource Grant of Location Petition to install one new pole in Swanton Street (J/O pole 149/20A) and the relocation of one additional pole on Swanton Street (J/O pole 149/21). The improvements are necessary to support the Town's Flood Mitigation Project at the Swanton Street bridge.

We find this petition to be acceptable subject to the following conditions:

- The petitioner must meet and satisfy all conditions of Exhibit A (attached);
- Installation shall be subject to the Town's Street Opening moratorium, which runs from November 15th through April 15th, at the discretion of the DPW Director;
- The conduit shall be installed by open excavation only (no tunneling);
- All underground utilities shall be adequately protected;
- All town-owned utilities shall be relocated at the applicant's expense, as needed;
- The conduit shall be installed/inspected by Eversource and duly recorded with Dig Safe.

cc: Jay Gill, DPW Director

Attachment: Exhibit A – Town of Winchester Grant of Location Requirements